

Must meet two or more of the conditions described in the box below:

If built before 2003 must meet three of the conditions

**For Homes Built After 2003**

1. Is there presence of sulfur-like or other unusual odors?
2. Is there confirmed presence of Chinese manufactured drywall in the home?
3. Is there copper corrosion, indicated by black, sooty coating of Un-insulated copper pipe leading to the air handler unit present in the garage or mechanical room of a home?
4. Is there documented failure of the air conditioner evaporator coil? (located inside air handling unit)
5. Is there confirmation by an outside expert or professional for the presence of premature copper corrosion on Un-insulated copper wires and/or air conditioner evaporator coils? (located inside air handling unit)

NOTE: Evaluation is based on current understanding of Defective Chinese Drywall manufacturing and the off gassing of chemicals. Please be aware the discovery of new facts occurs regularly and that may change your and my understanding of the affects of drywall manufactured in China or elsewhere in the world.